



Addendum #3

April 11, 2017

1133 East Second Wichita, KS 67214

phone: 316.262.7400

fax: 316.262.6880

project no.: **PK24416100**
project: **Burlington HS-MS Science Rooms Remodel**
address: **720 & 830 Cross St**
Burlington, Kansas 66839

The contractor shall include this addendum as a part of his proposal. This addendum forms a part of the contract documents. The following items are to change and or clarify the drawings and specifications for construction of the referenced building and shall take precedence over the original drawings and specifications where a conflict occurs.

CHANGES TO PRIOR ADDENDA

1.01 ADDENDUM #2:

A. Pre-Bid Attendance Roster: email address for Krayton Cox should be: cox_krayton@yahoo.com.

SPECIFICATIONS

2.01 Add attached COLOR KEY

DRAWINGS

3.01 Sheet M-A101 – FLOOR PLAN

A. ROOM FINISH SCHEDULE

1. ROOM M102 STEAM: Floor to be T-01, T-02.

3.02 Sheet H-E201 – FLOOR PLAN – POWER

A. Provide a 30A/208V/2P disconnect for power connection to air compressor located in Electrical room H108. Provide a new 30A, 2-pole breaker in existing panel S or panel PP1 made possible thru demolition of existing electrical devices. Provide (2) #10, #10G, 1/2" C. to air compressor. Coordinate electrical requirements with equipment manufacture prior to rough-in.

END OF ADDENDUM #3

PK24416100

SCIENCE ROOMS REMODEL

COLOR KEY

04/10/17

| Mark | Manuf. | Style Name | Color | Size | Installation | Special Instructions | Image |
|-----------------|------------------|-------------------------------------|------------------|-------------------|--|--|---|
| FLOORING | | | | | | | |
| CPT-01 | Patcraft | Big Splash! I0166 | Belly Flop 00813 | 24" x 24" | REF. FINISH PLAN | This carpet is being installed through out the rest of the high school. Contact Margarito Salono for more information. |  |
| RB-01 | Roppe | Standard Toe | MATCH EXIST | 4" Cove - Coil | - | |  |
| T-01 | Fritztile | Classic Terrazzo | DAWN C521533 | 12" x 12" x 3/16" | REF. FINISH PLAN | |  |
| T-02 | Fritztile | Natural Quarry | CAYENNE Q160262 | 12" x 12" x 3/16" | REF. FINISH PLAN | | |
| PAINT | | | | | | | |
| PNT-01 | Sherwin Williams | - | MATCH EXIST | - | - | - | |
| CEILING | | | | | | | |
| SAT-01 | Armstrong | School Zone Fine Fissured, NRC = .7 | 1714 | 48" x 24" | Field Grid Profile: Prelude - 15/16" - White | Ref. Lighting Plan | |
| SAT-02 | Armstrong | School Zone Fine Fissured, NRC = .7 | 1714 | 48" x 24" | Field Grid Profile: Prelude - 15/16" - White | Ref. Lighting Plan | |
| MISC | | | | | | | |
| FB-01 | Phifer | SunTex 90 Design | Walnut | Field Verify | | | |

CK-01

PBA Architects ©2016

GRAPHICS SHOWN MAY NOT REPRESENT THE TRUE COLOR OF THE SAMPLE. PHYSICAL SAMPLE MUST BE SUBMITTED AND APPROVED.